



# Managing the risk of 120v electric shock – Outcomes from recent electric shock events

Ben Stevenson, Superintendent Shaft Delivery

Robin Butler, Principal Electrical Engineer



# Electric shock events in the Jansen shafts

- Shock received when using a pendent for an electric hoist
- Shock received when retrieving a bell knocker rope



# Events


## 1. Winch Pendant 120V control



Managing the risk of 120v electric shock


1 March 2018

## 2. Bell Knocker Cables



# Shaft conditions while sinking

- Upcast shaft
- Ground surrounding shafts is frozen to ~700m
- Inside the shaft, conditions vary from cold and dry to snow, fog and even rain



# Wet conditions


Shaft liner and bracket



Floor of Shaft Boring Roadheader (SBR)



# Frosty conditions



# Causes

## 1. Electric winch shock – equipment not suited to environment

- No ground provision
- Systems not reviewed for potential hazards in wet conditions
- Equipment design and selection did not consider all potential operating conditions


## 2. Bell system shock

- Material buildup pulled the cable sheath back, exposing conductor
- Change Management that occurred did not include a review of Electrical Inspections and Controls
- Frequent human interaction = frequent exposure to hazard



# Lessons learned

- 120v circuits can be fatal – treat them as such!
- GFCI protection beyond what is required by code
- When conditions change, review potential hazards and risks with a broad spectrum of experts



**BHP**